

BERSCH & ASSOCIATES LTD.

September 21st, 2016

City of Saskatoon
222 3rd Avenue North
Saskatoon, SK
S7K 0J5

ATTENTION: Hazel Fernandez

SUBJECT: Bulk Sample Analysis Report – Forest Farm Park and Zoo

Please find attached the laboratory results for the bulk samples collected from the Forestry Farm Park and Zoo on September 14th, 2016 located at 1903 Forestry Farm Park Dr, Saskatoon, SK. The samples were analyzed for the identification of asbestos. Asbestos **was not** detected in the samples.

The results for the samples submitted were obtained by examination in accordance with the current USEPA 600/R-93/116 Method for the analysis of asbestos in building materials using polarized light microscopy and dispersion staining techniques. The detection limit of this method is listed as less than 1% by volume.

This test report relates only to the materials sent for examination and any use or extension of the information by the client of these results is the responsibility of the client.

If any questions arise on the results of the attached information, please contact our office 306 222 7477. Thank you for this opportunity of service!

Sincerely,



Brad Berschiminsky
Bersch & Associates Ltd.

File: B67BLI14F

Bersch & Associates Ltd.

B67BAI14F

Box 3568

Humboldt, Sask. S0K 2A0

BULK SAMPLE ANALYSIS REPORT**PROJECT NO: B67.16****CLIENT: CITY OF SASKATOON****CONTACT: HAZEL FERNANDEZ****LOCATION: FORESTRY FARM ZOO**

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST
1	14-Sep-16	Storage Room (Old Bunkhouse) - Stipple Ceiling Texture	No Asbestos Detected		WB
2	14-Sep-16	Office Room (Old Bunkhouse) - 1' x 1' Ceiling Tile	No Asbestos Detected		WB
3	14-Sep-16	Kitchen (Old Bunkhouse) - Sheet Flooring Grey W/ Fleck Pattern	No Asbestos Detected		WB
4	14-Sep-16	NE Room 2nd Floor (Old Bunkhouse) - Corkboard	No Asbestos Detected		WB
5	14-Sep-16	SW Room 2nd Floor (Old Bunkhouse) - Ceiling Plaster	No Asbestos Detected		WB
6	14-Sep-16	SW Room Attic Stairwell (Old Bunkhouse) - Ceiling Plaster	No Asbestos Detected		WB
7	14-Sep-16	SW Room Attic Stairwell (Old Bunkhouse) - Sheet Flooring Brown W/ Green	No Asbestos Detected		WB

Bersch & Associates Ltd.

B67BAI14F

Box 3568

Humboldt, Sask. S0K 2A0

BULK SAMPLE ANALYSIS REPORT**PROJECT NO: B67.16****CLIENT: CITY OF SASKATOON****CONTACT: HAZEL FERNANDEZ****LOCATION: FORESTRY FARM ZOO**

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST
8	14-Sep-16	Basement Cellar Room (Old Bunkhouse) - Sheet Flooring Orange	No Asbestos Detected		WB
9	14-Sep-16	Basement Chimney (Old Bunkhouse) - Brick Mortar	No Asbestos Detected		WB
10	14-Sep-16	Straw Storage Quonset - Shingle	No Asbestos Detected		WB
11	14-Sep-16	Basement Piller (Lunchroom) - Brick Mortar	No Asbestos Detected		WB
12	14-Sep-16	Blacksmith Shed - Chimney Brick Mortar	No Asbestos Detected		WB
13	14-Sep-16	Basement Stairwell (Superintendent Residence) - Brick Mortar	No Asbestos Detected		WB
14	14-Sep-16	Basement Stairwell (Superintendent Res.) - Chimney Brick Mortar	No Asbestos Detected		WB

Bersch & Associates Ltd.

B67BAI14F

Box 3568

Humboldt, Sask. S0K 2A0

BULK SAMPLE ANALYSIS REPORT**PROJECT NO: B67.16****CLIENT: CITY OF SASKATOON****CONTACT: HAZEL FERNANDEZ****LOCATION: FORESTRY FARM ZOO**

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST
15	14-Sep-16	Attic Middle (Superintendent Res.) - Insulation	No Asbestos Detected		WB
16	14-Sep-16	Attic East Wall (Superintendent Res.) - Insulation	No Asbestos Detected		WB
17	14-Sep-16	2nd Floor (Superintendent Res.) - Plaster Wall	No Asbestos Detected		WB
18	14-Sep-16	Basement Mens Washroom (Lunchroom) - Ceiling Tile	No Asbestos Detected		WB
19	14-Sep-16	Concession Booth - Linoleum	No Asbestos Detected		WB
20	14-Sep-16	Stairwell (Horse Barn) - Linoleum	No Asbestos Detected		WB
21	14-Sep-16	Shed (West of Quarantine) - Tar Paper	No Asbestos Detected		WB