

BERSCH & ASSOCIATES LTD.

November 21, 2016

City of Saskatoon
Facilities and Fleet Management
3130 Laurier Drive
Saskatoon, Sk
S7L 5J7

ATTENTION: Brent Anderson

SUBJECT: Asbestos Site Investigation – 940 River Landing Pavilion, Kitchen Upgrade Project.

Brad Berschiminsky of Bersch & Associates Ltd. conducted a site visit on October 14, 2016 to investigate and collect bulk samples of material to confirm there was no asbestos content. The facility was constructed in 2010 and is located at 940 River Landing Pavilion, Saskatoon, SK. One sample was collected and analyzed for the identification of asbestos. Asbestos **was not** detected within the sample of the concrete slab. Based on the bulk sampling and site investigation there does not appear to be an asbestos concern that would reflect on the kitchen renovation proposed for the area.

The results for the bulk sample was obtained by examination in accordance with the current USEPA 600/R-93/116 Method for the analysis of asbestos in building materials using polarized light microscopy and dispersion staining techniques. The detection limit of this method is listed as less than 1% by volume.

The Pavilion consists of a concrete slab, cinder block walls and tongue and groove wood construction on the ceiling/underside of roof. Refer to the attached photos. The south block wall was drilled into resulting in a hollow block cavity. No insulation was observed in the block wall. Refer to photo 1.

This test report relates only to the materials sent for examination and any use or extension of the information by the client of these results is the responsibility of the client. If any questions arise on the results of the attached information, please contact our office 306 222 7477. Thank you for this opportunity of service!

Sincerely,



Brad Berschiminsky
Bersch & Associates Ltd.
File: B67BLK14F River Landing Pavilion

P.O BOX 3568 HUMBOLDT, SK. S0K 2A0 Ph: (306) 231-5818 Fax: (306) 682-4509

SITE PHOTOS

**PHOTO 1 – SOUTHWEST CORNER BLOCK WALL
Empty Cavity**



PHOTO 2 – CEILING T & G WOODEN STRUCTURE



Bersch & Associates Ltd.

B67BAK14F

Box 3568
Humboldt, Sask. S0K 2A0**BULK SAMPLE ANALYSIS REPORT****PROJECT NO: B67.16**
CLIENT: CITY OF SASKATOON
CONTACT: BRENT ANDERSON
LOCATION: 940 RIVER LANDING PAVILION

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST
1	14-Nov-16	Kitchen / Mechanical Room - Compilation Sample Of Concrete Slab	No Asbestos Detected		WB